

Asset Management at Mercury

Mathew Hunt
Strategic Asset Planner




21 JUNE 2018

PERSONAL INTRODUCTION



- > BE Hons (Mech), University of Canterbury, 2010
- > Master Of Maintenance and Reliability Engineering, Federation University (Melbourne, Australia), 2018
- > Mercury (then Mighty River Power) in 2013
- > For fun, I ride mountain bikes






3 ASSET MANAGEMENT AT MERCURY





4 ASSET MANAGEMENT AT MERCURY





5 ASSET MANAGEMENT AT MERCURY





Asset Group Strategy

HV Electrical –

Indoor Circuit Breakers

PREPARED BY: Infrastructure Asset Management Team
REVIEWED: In accordance with Approvals Matrix v1.5
SIGNED OFF BY: Infrastructure Asset Manager
Hydro Generation Manager
Geothermal Field Manager

Signature

Date

VERSION: 0.2
STATUS: FINAL
VERSION DATE: 07th November 2017
FIRST ISSUED: 29th March 2017

DISTRIBUTION

This document is intended for distribution to / has been distributed to:

Copy No	Distribution List



TABLE OF CONTENTS

Asset Management Strategy	1
Glossary	1
Strategy Summary	2
Objectives	2
Key Strategy Statements	2
Triggers for Refurbishment	2
Triggers for Replacement	2
Contingency	3
Exceptions to the strategy	3
1 Asset Overview	4
1.1 Scope	4
1.2 Portfolio List	
1.3 Environment	
2 Performance / Standard	
2.1 Design	
2.2 Procurement	
2.3 Expected Life	
2.4 Operation	
2.5 Maintenance	
3 Maintenance / FMECA	
3.1 Current Maintenance Plans	
3.2 FMECA	
3.2.1 Risk Appetite / Criticality	
3.2.2 Risk Assessment	
3.2.3 Mitigations and Management	
4 Condition Assessment	
5 Contingency / Spares Management	
5.1 Spares strategy	
6 Logistics	
6.1 Personnel: Skill and Competency	
6.2 Tools	
6.3 Procurement	
6.3.1 Suppliers	
6.3.2 Stores	
6.3.3 Disposal	

EXCITATION MANAGEMENT STRATEGY SUMMARY

1 Objectives

To provide guidance in the proactive management and timely replacement of all excitation systems, taking into consideration the following:

- Ensure Excitation systems are operated within manufacturer's recommendations and design limits
- Performance targets (steady state and dynamic operational response) are met or exceeded
- Based on obsolescence, spares availability and risk assessment, actively replace excitation systems to reduce the probability of un-repairable hardware and software failures or uneconomic repairs
- Ensure all maintenance including preventative maintenance and condition monitoring routines, are adhered to within the prescribed specifications and schedules
- Ensure all excitation systems procured are capable of meeting current and any planned generator upgrades (where economically viable)
- Ensure that excitation systems meet EIPC requirements.

2 Key Strategy Statements

- The life expectancy of electronic excitation systems is 15-20 years (both digital and analogue) and 10-15 years for PLC based excitation systems
- Life expectancy of existing and the selection of new excitation systems is governed by spares availability, OEM support, environmental conditions, availability of technical skills and ability to meet EIPC requirements
- Standardise excitation systems to a limited number of manufacturers, minimising the number of spares held and resources required without going to a single manufacturer across the whole fleet.

3 Spares Strategy

- Set and hold minimum spares (serviceable) stock levels for each excitation system type, as determined by criticality analysis, where it is economically viable.
- Failed components will be repaired or discarded based on economics and future support requirements
- Spares shall be stored and managed to ensure they are kept in a serviceable state.


4 Excitation Replacement Triggers


Excitation systems will be proactively replaced, with due consideration to risk, when any one of the following occur:

Two “strategies/guidelines” two different maturity levels



7





8 ASSET MANAGEMENT AT MERCURY



Condition – Risk Heatmap (Asset Intervention Map)

Generation Type

Hydro

Risk Format

Highest Risk

Installed Capacity (MW)

Installed Year

Asset Groups

	Intake Gates
Water Passages	Penstocks
	Scroll Case
	Draft Tube
Turbines	Hydro Turbines
Governors	Hydro Governors
	Excitation
Generators	Hydro Generators
	Hydro Bearings
Circuit Breakers	HV Outdoor (110-220 kV)
	HV Indoor (3.3-11 kV)
Transformers	Transformers

Aratiatia						Ohakuri						Atiamuri									
90 MW Station Output						112 MW Station Output						84 MW Station Output									
1		2		3		1		2		3		4		1		2		3		4	
30		30		30		28		28		28		28		21		21		21		21	
1964		1964		1964		1961		1961		1961		1961		1958		1958		1958		1958	
I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK
D-H	FIN	B-M	FIN	D-H	FIN	B-M	FIN	B-M	FIN	B-M	FIN	B-M	FIN	A-H	FIN	A-H	FIN	A-H	FIN	A-H	FIN
C-H	H&S	C-H	H&S	C-H	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S
C-M	H&S	C-M	H&S	C-M	H&S	A-H	H&S	A-M	H&S	A-H	H&S	A-M	H&S	D-H	H&S	C-H	H&S	D-H	H&S	C-H	H&S
C-L	OPS	C-L	OPS	C-L	OPS	A-H	OPS	A-M	OPS	A-H	OPS	A-M	OPS	D-H	OPS	C-H	OPS	D-H	OPS	C-H	OPS
B-M	OPS	A-H	OPS	B-H	OPS	A-H	OPS	A-M	OPS	A-H	OPS	A-M	OPS	D-H	FIN	C-H	FIN	D-H	FIN	C-H	FIN
A-H	OPS	A-H	OPS	A-H	OPS	A-M	OPS	A-M	OPS	A-M	OPS	A-M	OPS	B-L	OPS	B-H	OPS	A-H	OPS	A-H	OPS
B-M	FIN	A-H	FIN	B-M	FIN	A-H	FIN	A-H	FIN	A-H	FIN	A-H	FIN	D-M	FIN	D-M	FIN	D-M	FIN	D-M	FIN
C-M	FIN	A-H	FIN	C-M	FIN	A-H	FIN	A-H	FIN	A-H	FIN	A-H	FIN	X-L	OPS	C-H	OPS	C-H	OPS	X-L	OPS
X-L	OPS	A-H	OPS	X-L	OPS	A-M	OPS	A-M	OPS	A-M	OPS	A-M	OPS	D-H	OPS	D-H	OPS	D-H	OPS	D-H	OPS
A-H	COM	A-H	OPS	A-H	OPS	C-H	OPS	C-H	OPS	C-H	OPS	C-H	OPS	B-H	OPS	B-H	OPS	B-H	OPS	B-H	OPS
C-M	OPS	C-M	OPS	B-H	OPS	D-H	OPS	C-M	OPS	B-H	OPS	B-L	OPS	B-H	OPS	B-H	OPS	B-H	OPS	B-H	OPS


The Heatmap represents the overall Intervention period and Critical Risk for each asset type (portfolio) and/or Station.

Within the Heatmap, users are able to access the details of that intervention or risk rating including its underlying condition score in the Asset's Condition Assessment by clicking on an individual cell.



Condition – Risk Heatmap (Asset Intervention Map)

Legend:



W2W Map 2018

Generation Type

Hydro

Risk Format

Highest Risk

Installed Capacity (MW)

Installed Year

Asset Groups	
Intake Gates	
Water Passages	Penstocks
	Scroll Case
	Draft Tube
Turbines	Hydro Turbines
Governors	Hydro Governors
Generators	Excitation
	Hydro Generators
	Hydro Bearings
Circuit Breakers	HV Outdoor (110-220 kV)
	HV Indoor (3.3-11 kV)
Transformers	Transformers


Aratiatia						Ohakuri						Atiamuri					
90 MW Station Output						112 MW Station Output						84 MW Station Output					
1	2	3	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3
30	30	30	28	28	28	28	21	21	21	21	21	21	21	21	21	21	21
1964	1964	1964	1961	1961	1961	1961	1958	1958	1958	1958	1958	1958	1958	1958	1958	1958	1958
I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK	I	RISK
D-H	FIN	B-M	FIN	D-H	FIN	B-M	FIN	B-M	FIN	B-M	FIN	A-H	FIN	A-H	FIN	A-H	FIN
C-H	H&S	C-H	H&S	C-H	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S	B-M	H&S
C-M	H&S	C-M	H&S	C-M	H&S	A-H	H&S	A-M	H&S	A-H	H&S	D-H	H&S	C-H	H&S	D-H	H&S
C-L	OPS	C-L	OPS	C-L	OPS	A-H	OPS	A-M	OPS	A-H	OPS	D-H	OPS	C-H	OPS	D-H	OPS
B-M	OPS	A-H	OPS	B-H	OPS	A-H	OPS	A-M	OPS	A-H	OPS	D-H	FIN	C-H	FIN	D-H	FIN
A-H	OPS	A-H	OPS	A-H	OPS	A-M	OPS	A-M	OPS	A-M	OPS	B-L	OPS	B-H	OPS	A-H	OPS
B-M	FIN	A-H	FIN	B-M	FIN	A-H	FIN	A-H	FIN	A-H	FIN	D-M	FIN	D-M	FIN	D-M	FIN
C-M	FIN	A-H	FIN	C-M	FIN	A-H	FIN	A-H	FIN	A-H	FIN	X-L	OPS	C-H	OPS	C-H	OPS
X-L	OPS	A-H	OPS	X-L	OPS	A-M	OPS	A-M	OPS	A-M	OPS	D-H	OPS	D-H	OPS	D-H	OPS
A-H	COM	A-H	OPS	A-H	OPS	C-H	OPS	C-H	OPS	C-H	OPS	B-H	OPS	B-H	OPS	B-H	OPS
C-M	OPS	C-M	OPS	B-H	OPS	D-H	OPS	C-M	OPS	B-H	OPS	B-H	OPS	B-H	OPS	B-H	OPS



Condition – Risk Heatmap (Asset Intervention Map)

KAW Hotwell Pumps			KAW A								
INTERVENTION			C-H		Intervene 2-5 Years; High Evidence			Impeller has 2 years remaining service life according to the strategies estimated 12 year service life. Substantial cavitation damage was found in the January 2018 inspection, which was repaired at the time. The impellers should be replaced within the next 4 years.			
CRITICAL RISK			OPS		Significant Consequence; Unlikely Probability (OPERATIONAL)			The most likely failures could be recovered from within a week (provided spares are available). The plant would operate at 0%-50% generation capacity over this time. KAG production is ~100MW at \$80/MWH a days generation is worth around ~\$192,000. Some spares have high valves (\$250k for an impeller, \$350k for a motor.) Its likely any failure will result in financial impact >\$750k but <\$7.5m			
			Return Calculated Rating				Edit Assessment				
Assessment Date:			Jan-18								
Inspection Type:			Biennial Shut								
Intervention Assessment											
Pump Component	Estimated Replacement Lifecycle	Maintenance Lifecycle	Original Install Date	Date Replaced or Maintained	Age Since Overhaul (yrs)	Time Until Intervention (yrs)	Comments	Adjusted Time Until Intervention (yrs)	Level of Evidence	Intervention Rating	
Impeller/Suction bowl	12	8	Jan-08	Jan-08	10.0	2.0	Impeller has 2 years remaining service life according to the strategies estimated 12 year service life. Substantial cavitation damage was found in the January 2018 inspection, which was repaired at the time. The impellers should be replaced within the next 4 years.	4.0	High	C-H	
Motor	25	8	Jan-08	Jan-18	0.0	8.0	Motor was overhauled in Jan 2018 with new bearings installed. The electrical tests indicate that the rotor and stator are in good condition. It should be electrically tested in 4 years time but will last another 10 years until a routine overhaul is required.	10.0	High	B-H	
Bearings, Seals, Shafts and Consumables	8	8	Jan-08	Jan-18	0.0	8.0	Labyrinth bush was found to be heavily worn at Jan 2018 inspection. The labyrinth bush housing was found to be out of round and oversize, going from an interference fit to a clearance one, so the bush was reinstalled with liberal quantities of Loctite to hold in place. At the next overhaul opportunity consideration should be given to rebuilding and inspected in 2018. Good condition.		High	B-H	
Remainder of Pump (Discharge Bowl, column pipes etc.)	25	8	Jan-08	Jan-08	10.0	15.0	For outage reports and further evidence of condition see: \\mrp.net.nz\data\Departments\Generation Asset Strategy\Asset Specialist (mechanical)		High	A-H	





13 ASSET MANAGEMENT AT MERCURY




Life Cycle Plan - Operations Work List (OWL)

Hydro Planning by Asset - FY2019 to FY2034												
File Location: http://sharepoint/generation/asset-management-plan/Main Document Library/All Fuel - 15 yr Project Schedule.xlsx												
Financial Year												4
Class 4	Station A	G2		G3								
	Station B											
	Station C											
	Station D											
	Station E											
	Station F											
	Station G											
	Station H						G1	G3	G4	G1	G3	G2
	Station I											
Turbine Rerunning	Station A		G1									
	Station B											
	Station C					G3	G1	G4	G2			
	Station D	G2	G1	G4								
	Station E						G1	G2	G5	G4	G3	
	Station F											
	Station G											
	Station H											
	Station I				G2							
Generator Replacement	Station A	G2	G1	G3								
	Station B											
	Station C					G3	G1	G4	G2	G1	G2	G3
	Station D	G2	G1	G4								
	Station E						G1	G2	G5	G4	G3	
	Station F											
	Station G										G1	G2
	Station H										G3	
	Station I				G2							
Governor Replacement	Station A	G2	G1	G3								
	Station B											
	Station C											
	Station D	G2	G1	G4								
	Station E			G1/2/3	G4/5							
	Station F											
	Station G				G3	G2	G1					
	Station H	G8/6										
	Station I				G2	G1	G3					
Transformer Replacement	Station A				T2	T1						
	Station B				T2		T1	T3	T4			
	Station C				T3		T2	T1				
	Station D				T4							
	Station E	T3										
	Station F		T10		T6							





Monthly All Teams Resource Requirements for FY19 July to FY19

June
(sorted by Role)



Operations Work List (OWL)





Maintenance Management – Maximo, Eclipse and Asset Cataloguing

- > Maximo is used as the companies computerised maintenance management system
- > PM tasks are informed by the asset group guidelines:
 - > FMECA studies
 - > Compliance requirements (Geothermal Regulations, PECPR, EIPC etc.)
- > Current challenge with Maintenance management is lack of consistency (Maximo, Eclipse, Drawings etc.)
 - > Unreliable OEM drawings
 - > Assets exist physically but not on drawings, in maximo or in eclipse & Vice versa
 - > Typo's and language used (e.g vaporizer, vaporiser, vaporizor, vapouriser)
 - > Inconsistency within sites and across the business



Maintenance Management – Maximo, Eclipse and Asset Cataloguing

- > Development of the Asset Catalogue Standard
 - > KKS Location Coding system adapted for use at Mercury
 - > It provides standard rules that establish asset location code and description uniformity across Mercury (Geo, Hydro and Southdown)
 - > Asset Catalog Standard reviewed and endorsed by representatives from across the business
 - > Common terminology to be utilized, excess data moved to appropriate fields in Maximo, typos and spelling corrected.
 - > Will be applied in conjunction with the Asset Tagging Standard to ensure that equipment on site is appropriately labeled.



DATA EXAMPLE

Current Maximo Data

Asset Number	Asset Description	Location	Location Description	DCS Tag	Official Number
1005134	OEC3 Preheater (M&I A1140102)	MOK03/HAB53/AC001	OEC3 Preheater (M&I A1140102)	A1140102	A1140102
1002885	OEC11 LH Preheater (M&I 143073)	MOK11/HAB51/AC001	OEC11 LH Preheater (M&I 143073)	11-H-1101A	11-H-1101A
1002886	OEC11 RH Preheater (M&I 143071)	MOK11/HAB52/AC001	OEC11 RH Preheater (M&I 143071)	11-H-1101B	11-H-1101B
350874	OEC-1 Preheater HE-9102C ON# A1121008	NTM01/LGD51/AC001	OEC-1 Preheater HE-9102C ON# A1121008	1-HE-9102C	
350875	OEC-1 Preheater HE-9102B ON# A1121008	NTM01/LGD52/AC001	OEC-1 Preheater HE-9102B ON# A1121008	1-HE-9102B	
350876	OEC-1 Preheater HE-9102A ON# A1121007	NTM01/LGD54/AC001	OEC-1 Preheater HE-9102A ON# A1121007	1-HE-9102A	
1002932	OEC01 Preheater	RKA01/HAB50/AC001	OEC01 Preheater	MI 166040	MI 166040
1000152	OEC21 Preheater	RKA21/HAB50/AC001	OEC21 Preheater	H-1101	MI 144119

Asset Catalogue Standard Implemented Maximo Data

Asset Number	Asset Description	Location	Location Description	DCS Tag	Official Number
1005134	Heat Exchanger; Shell and Tube; Horizontal	MOK03/HAB53/AC001	OEC03 Preheater		MI A1140102
1002885	Heat Exchanger; Shell and Tube; Horizontal	MOK11/HAB51/AC001	OEC11 LH Preheater	11-H-1101A	MI 143073
1002886	Heat Exchanger; Shell and Tube; Horizontal	MOK11/HAB52/AC001	OEC11 RH Preheater	11-H-1101B	MI 143071
350874	Heat Exchanger; Shell and Tube; Horizontal	NTM01/HAB51/AC001	OEC01 Preheater C	01-HE-9102C	MI A1121008
350875	Heat Exchanger; Shell and Tube; Horizontal	NTM01/HAB52/AC001	OEC01 Preheater B	01-HE-9102B	MI A1121008
350876	Heat Exchanger; Shell and Tube; Horizontal	NTM01/HAB54/AC001	OEC01 Preheater A	01-HE-9102A	MI A1121007
1002932	Heat Exchanger; Shell and Tube; Horizontal	RKA01/HAB50/AC001	OEC01 Preheater		MI 166040
1000152	Heat Exchanger; Shell and Tube; Horizontal	RKA21/HAB50/AC001	OEC21 Preheater	21-H-1101	MI 144119



Questions?



